

https://www.phoenixcontact.com/us/products/2910323



Please be informed that the data shown in this PDF document is generated from our online catalog. Please find the complete data in the user documentation. Our general terms of use for downloads are valid.

300 mm long Rogowski coil. The measuring coil diameter when installed is 95 mm. The Rogowski coil is used for AC current measurement for busbars and power lines.



Commercial data

Item number	2910323
Packing unit	1 pc
Minimum order quantity	1 pc
Sales key	C444
Product key	CK4A12
Catalog page	Page 219 (C-5-2019)
GTIN	4055626437576
Weight per piece (including packing)	368.74 g
Weight per piece (excluding packing)	357 g
Customs tariff number	90309000
Country of origin	DE



https://www.phoenixcontact.com/us/products/2910323



Technical data

Product properties

Product type	Rogowski coil
Set comprises	2910326 PACT RCP-4000A-1A-D95-10M
Data management status	
Article revision	03
Insulation characteristics	

Electrical properties

Measuring coil

Conductor structure signal line	2x 0.22 mm (Signal (tinned))
	1x 0.22 mm (Shielding (tinned))
Insulation	double insulation
Rated insulation voltage	1000 V AC (rms CAT III)
	600 V AC (rms CAT IV)
Test voltage	10.45 kV DC (60 s)
Basic accuracy	<± 0.2 %

General

Converter type	Rogowski coil
----------------	---------------

Input data

Frequency

Designation	Measuring coil
Frequency measuring range	40 Hz 20000 Hz
Position error	<± 0.1 % (typical)
Linearity error	< 0.1 %

Current transformer

Output data

Signal

Designation	Measuring coil
Output signal (at 50 Hz)	100 mV (no load, at 1,000 A)
Output voltage (in no-load operation)	V _{OUT} = M * dl/dt
Output voltage (sinusoidal, in no-load operation)	100 mV (V_{OUT} = 2 * π * M * f * I (M = 0.318 μ H; example: At 50 Hz; I = 1,000 A))

Dimensions



https://www.phoenixcontact.com/us/products/2910323



Meas	urina	COIL

Length	300 mm
Diameter	8.3 mm ±0.2 mm
Measuring coil when installed	
Diameter	95 mm
Signal line	
Lenath	10 m

Material specifications

Housing material	PC
Coil material	Elastollan

Environmental and real-life conditions

Ambient conditions

Measuring coil degree of protection	IP54 (not assessed by UL)
Ambient temperature (operation)	-30 °C 80 °C (Measuring coil)
Ambient temperature (storage/transport)	-40 °C 80 °C (Measuring coil)
Altitude	< 2000 m
Permissible humidity (operation)	5 % 95 % (non-condensing)

Approvals

11	ıv	\sim	^
u	ı۲\	v	_

Certificate

CMIM		
Certificate	CMIM-compliant	
UL, USA/Canada		
UL, USA/Canada Identification	UL 61010 Recognized	

UKCA-compliant

Standards and regulations

Standards/regulations	IEC 61010-1
	IEC 61010-2-030
	IEC 61869-10

Mounting

Thread type	0



https://www.phoenixcontact.com/us/products/2910323



Approvals

To download certificates, visit the product detail page: https://www.phoenixcontact.com/us/products/2910323



cUL Recognized

Approval ID: FILE E 357804



UL RecognizedApproval ID: FILE E 357804

cULus Recognized



https://www.phoenixcontact.com/us/products/2910323



Classifications

UNSPSC 21.0

ECLASS

	ECLASS-11.0	27210992
	ECLASS-12.0	27210992
	ECLASS-13.0	27210992
ETIM		
	ETIM 9.0	EC002498
UN	SPSC	

39121000



https://www.phoenixcontact.com/us/products/2910323



Environmental product compliance

EU R	oHS
------	-----

Fulfills EU RoHS substance requirements	Yes, No exemptions
China RoHS	
Environment friendly use period (EFUP)	EFUP-E
	No hazardous substances above the limits
EU REACH SVHC	
REACH candidate substance (CAS No.)	No substance above 0.1 wt%



https://www.phoenixcontact.com/us/products/2910323



Accessories

PACT RCP-CLAMP - Holder

2904895

https://www.phoenixcontact.com/us/products/2904895



The optional holding device ensures the Rogowski coil is securely seated on busbars with a thickness of 10 ... 15 mm. During installation, the coil housing is pushed onto the flange of the holding device and snaps in automatically.

Phoenix Contact 2024 © - all rights reserved https://www.phoenixcontact.com

Phoenix Contact USA 586 Fulling Mill Road Middletown, PA 17057, United States (+717) 944-1300 info@phoenixcon.com