6AG1124-0GC01-4AX0

**Data sheet** 

SIPLUS HMI TP700 COMFORT FOR medial stress with conformal coating based on 6AV2124-0GC01-0AX0  $\,$ 



Figure similar

General information	
Product type designation	TP700 Comfort
Display	
Design of display	TFT
Screen diagonal	7 in
Display width	152.4 mm
Display height	91.4 mm
Number of colors	16 777 216
Resolution (pixels)	
<ul> <li>Horizontal image resolution</li> </ul>	800 pixel
Vertical image resolution	480 pixel
Backlighting	
<ul> <li>MTBF backlighting (at 25 °C)</li> </ul>	80 000 h
<ul> <li>Backlight dimmable</li> </ul>	Yes; 0-100 %
Control elements	
Keyboard fonts	
<ul> <li>Function keys</li> </ul>	
<ul> <li>Number of function keys</li> </ul>	0
<ul> <li>Number of function keys with LEDs</li> </ul>	0
<ul> <li>Keys with LED</li> </ul>	No
System keys	No
<ul> <li>Numeric keyboard</li> </ul>	Yes; Onscreen keyboard
alphanumeric keyboard	Yes; Onscreen keyboard
Touch operation	
Design as touch screen	Yes
Expansions for operator control of the process	
<ul> <li>DP direct LEDs (LEDs as S7 output I/O)</li> </ul>	
— F1Fx	0
<ul> <li>Direct keys (keys as S7 input I/O)</li> </ul>	
— F1Fx	0
<ul> <li>Direct keys (touch buttons as S7 input I/O)</li> </ul>	32
Installation type/mounting	
Mounting position	vertical
Wall mounting/direct mounting	No
Mounting in portrait format possible	Yes
Mounting in landscape format possible	Yes

maximum permissible angle of inclination without external ventilation	35°
Supply voltage	
Type of supply voltage	DC
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
	20.0 V
Input current	0.5.4
Current consumption (rated value)	0.5 A
Starting current inrush I²t	0.5 A <sup>2</sup> ·s
Power	
Active power input, typ.	12 W
Memory	
Flash	Yes
RAM	Yes
Memory available for user data	12 Mbyte
Type of output	
Info LED	No
Power LED	No
Error LED	No
Acoustics	
Buzzer	No
Speaker	Yes
Time of day	
Clock	
Hardware clock (real-time)	Yes
Software clock	No
• retentive	Yes; Back-up duration typically 6 weeks
<ul><li>synchronizable</li></ul>	Yes
o dynonicalic	
Interfaces	
	2
Interfaces	2 1; RS 422 / 485 combined
Interfaces  Number of industrial Ethernet interfaces	
Number of industrial Ethernet interfaces  Number of RS 485 interfaces	1; RS 422 / 485 combined
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces	1; RS 422 / 485 combined 1
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces	1; RS 422 / 485 combined 1
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces	1; RS 422 / 485 combined 1 0 2; USB 2.0
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B	1; RS 422 / 485 combined 1 0 2; USB 2.0 1; 5-pole
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 2
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 2
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  ● USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces  Industrial Ethernet	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 2 No
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces  Industrial Ethernet  • Industrial Ethernet status LED	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 2 No
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces  Industrial Ethernet  • Industrial Ethernet status LED  • Number of ports of the integrated switch	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 2 No
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces  Industrial Ethernet  • Industrial Ethernet status LED  • Number of ports of the integrated switch  Protocols  PROFINET	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 2 No
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces  Industrial Ethernet  • Industrial Ethernet status LED  • Number of ports of the integrated switch  Protocols	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 2 No  Yes
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces  Industrial Ethernet  • Industrial Ethernet status LED  • Number of ports of the integrated switch  Protocols  PROFINET  Supports protocol for PROFINET IO	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 2 No  Yes Yes
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces  Industrial Ethernet  • Industrial Ethernet status LED  • Number of ports of the integrated switch  Protocols  PROFINET  Supports protocol for PROFINET IO  IRT	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 0 2 No  2 No  Yes Yes Yes; As of WinCC V12
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces  Industrial Ethernet  • Industrial Ethernet status LED  • Number of ports of the integrated switch  Protocols  PROFINET  Supports protocol for PROFINET IO  IRT  PROFIBUS	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 0 2 No  2 Yes Yes Yes; As of WinCC V12 Yes
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces  Industrial Ethernet  • Industrial Ethernet status LED  • Number of ports of the integrated switch  Protocols  PROFINET  Supports protocol for PROFINET IO  IRT  PROFIBUS  MPI	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 0 2 No  2 Yes Yes Yes; As of WinCC V12 Yes
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces  Industrial Ethernet  • Industrial Ethernet status LED  • Number of ports of the integrated switch  Protocols  PROFINET  Supports protocol for PROFINET IO  IRT  PROFIBUS  MPI  Protocols (Ethernet)	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 0 2 No  2 No  Yes Yes Yes Yes, As of WinCC V12 Yes Yes
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces  Industrial Ethernet  • Industrial Ethernet status LED  • Number of ports of the integrated switch  Protocols  PROFINET  Supports protocol for PROFINET IO  IRT  PROFIBUS  MPI  Protocols (Ethernet)  • TCP/IP	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 0 2 No  2 No  Yes Yes Yes; As of WinCC V12 Yes Yes
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces  Industrial Ethernet  • Industrial Ethernet status LED  • Number of ports of the integrated switch  Protocols  PROFINET  Supports protocol for PROFINET IO  IRT  PROFIBUS  MPI  Protocols (Ethernet)  • TCP/IP  • DHCP	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 0 2 No  Yes Yes Yes Yes Yes Yes Yes Yes Yes
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces  Industrial Ethernet  • Industrial Ethernet status LED  • Number of ports of the integrated switch  Protocols  PROFINET  Supports protocol for PROFINET IO  IRT  PROFIBUS  MPI  Protocols (Ethernet)  • TCP/IP  • DHCP  • SNMP	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 0 2 No  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Interfaces  Number of industrial Ethernet interfaces  Number of RS 485 interfaces  Number of RS 422 interfaces  Number of RS 232 interfaces  Number of USB interfaces  • USB Mini B  Number of 20 mA interfaces (TTY)  Number of parallel interfaces  Number of other interfaces  Number of SD card slots  With software interfaces  Industrial Ethernet  • Industrial Ethernet status LED  • Number of ports of the integrated switch  Protocols  PROFINET  Supports protocol for PROFINET IO  IRT  PROFIBUS  MPI  Protocols (Ethernet)  • TCP/IP  • DHCP  • SNMP  • DCP	1; RS 422 / 485 combined  1 0 2; USB 2.0 1; 5-pole 0 0 0 2 No  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye

• HTTP	Yes
• HTTPS	No
• HTML	Yes
• XML	No
• CSS	Yes
<ul> <li>Active X</li> </ul>	No
JavaScript	Yes
• Java VM	No
Redundancy mode	
Media redundancy	
— MRP	Yes; As of WinCC V12
Further protocols	
• CAN	No
• EtherNet/IP	Yes
MODBUS	Yes
Interrupts/diagnostics/status information	163
Diagnoses	V 07 1 1
Diagnostic information readable	Yes; S7 controller
EMC	
Emission of radio interference acc. to EN 55 011	
<ul> <li>Limit class A, for use in industrial areas</li> </ul>	Yes
<ul> <li>Limit class B, for use in residential areas</li> </ul>	No
Degree and class of protection	
NEMA (front)	
Enclosure Type 4 at the front	Yes
Enclosure Type 4x at the front	Yes
Ambient conditions	
Suited for indoor use	Yes
Suited for outdoor use	No
Outled for outdoor use	110
Ambient temperature during operation	
Ambient temperature during operation	
Operation (vertical installation)	0°C: - Tmin
<ul><li>Operation (vertical installation)</li><li>— For vertical installation, min.</li></ul>	0 °C; = Tmin
<ul> <li>Operation (vertical installation)</li> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul>	0 °C; = Tmin 50 °C; = Tmax
<ul> <li>Operation (vertical installation)</li> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> <li>Operation (max. tilt angle)</li> </ul>	50 °C; = Tmax
<ul> <li>Operation (vertical installation)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle)         <ul> <li>At maximum tilt angle, min.</li> </ul> </li> </ul>	50 °C; = Tmax 0 °C; = Tmin
<ul> <li>Operation (vertical installation)</li> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> <li>Operation (max. tilt angle)</li> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul>	50 °C; = Tmax
<ul> <li>Operation (vertical installation)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle)         <ul> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul> </li> <li>Operation (vertical installation, portrait format)</li> </ul>	50 °C; = Tmax 0 °C; = Tmin 40 °C; = Tmax
<ul> <li>Operation (vertical installation)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle)         <ul> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul> </li> <li>Operation (vertical installation, portrait format)         <ul> <li>For vertical installation, min.</li> </ul> </li> </ul>	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin
<ul> <li>Operation (vertical installation)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle)         <ul> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul> </li> <li>Operation (vertical installation, portrait format)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> </ul>	50 °C; = Tmax 0 °C; = Tmin 40 °C; = Tmax
<ul> <li>Operation (vertical installation)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle)         <ul> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul> </li> <li>Operation (vertical installation, portrait format)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle, portrait format)</li> </ul>	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax
<ul> <li>Operation (vertical installation)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle)         <ul> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul> </li> <li>Operation (vertical installation, portrait format)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle, portrait format)         <ul> <li>At maximum tilt angle, min.</li> </ul> </li> </ul>	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin
<ul> <li>Operation (vertical installation)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle)         <ul> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul> </li> <li>Operation (vertical installation, portrait format)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle, portrait format)         <ul> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul> </li> </ul>	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax
<ul> <li>Operation (vertical installation)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle)         <ul> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul> </li> <li>Operation (vertical installation, portrait format)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle, portrait format)         <ul> <li>At maximum tilt angle, min.</li> </ul> </li> </ul>	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmax  0 °C; = Tmax
<ul> <li>Operation (vertical installation)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle)         <ul> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul> </li> <li>Operation (vertical installation, portrait format)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle, portrait format)         <ul> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul> </li> </ul>	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmax  -20 °C
<ul> <li>Operation (vertical installation)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle)         <ul> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul> </li> <li>Operation (vertical installation, portrait format)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle, portrait format)         <ul> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul> </li> <li>Ambient temperature during storage/transportation</li> <li>min.</li> <li>max.</li> </ul>	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 35 °C; = Tmax
<ul> <li>Operation (vertical installation)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle)         <ul> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul> </li> <li>Operation (vertical installation, portrait format)         <ul> <li>For vertical installation, min.</li> <li>For vertical installation, max.</li> </ul> </li> <li>Operation (max. tilt angle, portrait format)         <ul> <li>At maximum tilt angle, min.</li> <li>At maximum tilt angle, min.</li> </ul> </li> <li>Ambient temperature during storage/transportation</li> <li>min.</li> </ul>	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmin 40 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 35 °C; = Tmax
Operation (vertical installation)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle)  At maximum tilt angle, min.  At maximum tilt angle, min.  Operation (vertical installation, portrait format)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle, portrait format)  At maximum tilt angle, min.  At maximum tilt angle, min.  At maximum tilt angle, min.  Ambient temperature during storage/transportation  min.  max.  Altitude during operation relating to sea level  Installation altitude above sea level, max.	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmin 40 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 35 °C; = Tmax
Operation (vertical installation)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle)  At maximum tilt angle, min.  At maximum tilt angle, min.  Operation (vertical installation, portrait format)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle, portrait format)  At maximum tilt angle, min.  Altitude during operation relating to sea level  Installation altitude above sea level, max.  Ambient air temperature-barometric pressure-	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmax  0 °C; = Tmax  -20 °C 60 °C  5 000 m Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) // Tmin
Operation (vertical installation)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle)  At maximum tilt angle, min.  At maximum tilt angle, min.  Operation (vertical installation, portrait format)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle, portrait format)  At maximum tilt angle, min.  At maximum tilt angle, min.  At maximum tilt angle, min.  Ambient temperature during storage/transportation  min.  max.  Altitude during operation relating to sea level  Installation altitude above sea level, max.	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 35 °C; = Tmax  -20 °C 60 °C  5 000 m Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) // Tmin (Tmax - 10 K) at 795 hPa 658 hPa (+2 000 m +3 500 m) // Tmin
Operation (vertical installation)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle)  At maximum tilt angle, min.  At maximum tilt angle, min.  Operation (vertical installation, portrait format)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle, portrait format)  At maximum tilt angle, min.  Altitude during operation relating to sea level  Installation altitude above sea level, max.  Ambient air temperature-barometric pressure-altitude	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmax  0 °C; = Tmax  -20 °C 60 °C  5 000 m Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) // Tmin
Operation (vertical installation)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle)  At maximum tilt angle, min.  At maximum tilt angle, min.  Operation (vertical installation, portrait format)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle, portrait format)  At maximum tilt angle, min.  At maximum tilt angle, min.  At maximum tilt angle, min.  Installation altitude above sea level  Installation altitude above sea level  Relative humidity	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 35 °C; = Tmax  -20 °C 60 °C  5 000 m  Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) // Tmin (Tmax - 10 K) at 795 hPa 658 hPa (+2 000 m +3 500 m) // Tmin (Tmax -20 K) at 658 hPa 540 hPa (+3 500 m +5 000 m)
Operation (vertical installation)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle)  At maximum tilt angle, min.  At maximum tilt angle, min.  Operation (vertical installation, portrait format)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle, portrait format)  At maximum tilt angle, min.  At maximum tilt angle, min.  At maximum tilt angle, min.  Installation altitude above sea level  Installation altitude above sea level, max.  Ambient air temperature-barometric pressure-altitude  Relative humidity  With condensation, tested in accordance with IEC	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 35 °C; = Tmax  -20 °C 60 °C  5 000 m  Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) // Tmin (Tmax - 10 K) at 795 hPa 658 hPa (+2 000 m +3 500 m) // Tmin (Tmax -20 K) at 658 hPa 540 hPa (+3 500 m +5 000 m)
Operation (vertical installation)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle)  At maximum tilt angle, min.  At maximum tilt angle, min.  Operation (vertical installation, portrait format)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle, portrait format)  At maximum tilt angle, min.  At maximum tilt angle, min.  At maximum tilt angle, min.  In temperature during storage/transportation  min.  max.  Altitude during operation relating to sea level  Installation altitude above sea level, max.  Ambient air temperature-barometric pressure-altitude  Relative humidity  With condensation, tested in accordance with IEC 60068-2-38, max.	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 35 °C; = Tmax  -20 °C 60 °C  5 000 m  Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) // Tmin (Tmax - 10 K) at 795 hPa 658 hPa (+2 000 m +3 500 m) // Tmin (Tmax -20 K) at 658 hPa 540 hPa (+3 500 m +5 000 m)
Operation (vertical installation)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle)  At maximum tilt angle, min.  At maximum tilt angle, min.  Operation (vertical installation, portrait format)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle, portrait format)  At maximum tilt angle, min.  Ambient temperature during storage/transportation  min.  max.  Altitude during operation relating to sea level  Installation altitude above sea level, max.  Ambient air temperature-barometric pressure-altitude  Relative humidity  With condensation, tested in accordance with IEC 60068-2-38, max.  Resistance	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 35 °C; = Tmax  -20 °C 60 °C  5 000 m  Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) // Tmin (Tmax - 10 K) at 795 hPa 658 hPa (+2 000 m +3 500 m) // Tmin (Tmax -20 K) at 658 hPa 540 hPa (+3 500 m +5 000 m)
Operation (vertical installation)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle)  At maximum tilt angle, min.  At maximum tilt angle, min.  Operation (vertical installation, portrait format)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle, portrait format)  At maximum tilt angle, min.  Ambient temperature during storage/transportation  min.  max.  Altitude during operation relating to sea level  Installation altitude above sea level, max.  Ambient air temperature-barometric pressure-altitude  Relative humidity  With condensation, tested in accordance with IEC 60068-2-38, max.  Resistance  Coolants and lubricants	50 °C; = Tmin 40 °C; = Tmin 40 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 35 °C; = Tmax  -20 °C 60 °C  5 000 m  Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) // Tmin (Tmax - 10 K) at 795 hPa 658 hPa (+2 000 m +3 500 m) // Tmin (Tmax -20 K) at 658 hPa 540 hPa (+3 500 m +5 000 m)  100 %; RH incl. condensation/frost (no commissioning under condensation conditions)
Operation (vertical installation)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle)  At maximum tilt angle, min.  At maximum tilt angle, min.  Operation (vertical installation, portrait format)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle, portrait format)  At maximum tilt angle, min.  At maximum tilt angle, min.  At maximum tilt angle, min.  Ambient temperature during storage/transportation  min.  max.  Altitude during operation relating to sea level  Installation altitude above sea level, max.  Ambient air temperature-barometric pressure-altitude  Relative humidity  With condensation, tested in accordance with IEC 60068-2-38, max.  Resistance	50 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 35 °C; = Tmax  -20 °C 60 °C  5 000 m  Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) // Tmin (Tmax - 10 K) at 795 hPa 658 hPa (+2 000 m +3 500 m) // Tmin (Tmax -20 K) at 658 hPa 540 hPa (+3 500 m +5 000 m)
Operation (vertical installation)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle)  At maximum tilt angle, min.  At maximum tilt angle, min.  Operation (vertical installation, portrait format)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle, portrait format)  At maximum tilt angle, min.  At maximum tilt angle, min.  At maximum tilt angle, min.  Ambient temperature during storage/transportation  min.  max.  Altitude during operation relating to sea level  Installation altitude above sea level, max.  Ambient air temperature-barometric pressure-altitude  Relative humidity  With condensation, tested in accordance with IEC 60068-2-38, max.  Resistance  Coolants and lubricants  Resistant to commercially available coolants and lubricants	50 °C; = Tmin 40 °C; = Tmin 40 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 35 °C; = Tmax  -20 °C 60 °C  5 000 m  Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) // Tmin (Tmax - 10 K) at 795 hPa 658 hPa (+2 000 m +3 500 m) // Tmin (Tmax -20 K) at 658 hPa 540 hPa (+3 500 m +5 000 m)  100 %; RH incl. condensation/frost (no commissioning under condensation conditions)
Operation (vertical installation)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle)  At maximum tilt angle, min.  At maximum tilt angle, min.  Operation (vertical installation, portrait format)  For vertical installation, min.  For vertical installation, max.  Operation (max. tilt angle, portrait format)  At maximum tilt angle, min.  At maximum tilt angle, min.  At maximum tilt angle, min.  Ambient temperature during storage/transportation  min.  max.  Altitude during operation relating to sea level  Installation altitude above sea level, max.  Ambient air temperature-barometric pressure-altitude  Relative humidity  With condensation, tested in accordance with IEC 60068-2-38, max.  Resistance  Coolants and lubricants  Resistant to commercially available coolants	50 °C; = Tmin 40 °C; = Tmin 40 °C; = Tmin 40 °C; = Tmax  0 °C; = Tmin 35 °C; = Tmax  -20 °C 60 °C  5 000 m  Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) // Tmin (Tmax - 10 K) at 795 hPa 658 hPa (+2 000 m +3 500 m) // Tmin (Tmax -20 K) at 658 hPa 540 hPa (+3 500 m +5 000 m)  100 %; RH incl. condensation/frost (no commissioning under condensation conditions)

EN 60721-3-3	fauna); Class 3B3 on request
<ul> <li>to chemically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *
<ul> <li>to mechanically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3S4 incl. sand, dust, *
Use on ships/at sea	
<ul> <li>to biologically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6B2 mold and fungal spores (excluding fauna); Class 6B3 on request
<ul> <li>to chemically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *
<ul> <li>to mechanically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6S3 incl. sand, dust; *
Usage in industrial process technology	
<ul> <li>Against chemically active substances acc. to EN 60654-4</li> </ul>	Yes; Class 3 (excluding trichlorethylene)
<ul> <li>Environmental conditions for process, measuring and control systems acc. to ANSI/ISA- 71.04</li> </ul>	Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil)
Remark	( )
<ul> <li>Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04</li> </ul>	* The supplied plug covers must remain in place over the unused interfaces during operation!
Conformal coating	
<ul> <li>Coatings for printed circuit board assemblies acc. to EN 61086</li> </ul>	Yes; Class 2 for high reliability
<ul> <li>Protection against fouling acc. to EN 60664-3</li> </ul>	Yes; Type 1 protection
<ul> <li>Military testing according to MIL-I-46058C, Amendment 7</li> </ul>	Yes; Discoloration of coating possible during service life
<ul> <li>Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC-CC-830A</li> </ul>	Yes; Conformal coating, Class A
Operating systems	
nun mintem .	
proprietary	No
proprietary pre-installed operating system	No
	Yes
pre-installed operating system	
pre-installed operating system  • Windows CE	
pre-installed operating system  • Windows CE  Configuration  Message indicator	Yes
pre-installed operating system  • Windows CE  Configuration	Yes Yes
pre-installed operating system  • Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)	Yes Yes Yes
pre-installed operating system  • Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)  Process value display (output)	Yes Yes Yes Yes Yes
pre-installed operating system  • Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)  Process value display (output)  Process value default (input) possible	Yes Yes Yes Yes Yes Yes
pre-installed operating system  • Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)  Process value display (output)  Process value default (input) possible  Recipe management	Yes Yes Yes Yes Yes Yes
pre-installed operating system  • Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)  Process value display (output)  Process value default (input) possible  Recipe management  Configuration software	Yes Yes Yes Yes Yes Yes Yes Yes
pre-installed operating system  • Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)  Process value display (output)  Process value default (input) possible  Recipe management  Configuration software  • STEP 7 Basic (TIA Portal)	Yes Yes Yes Yes Yes Yes Yes Yes No
pre-installed operating system  • Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)  Process value display (output)  Process value default (input) possible  Recipe management  Configuration software  • STEP 7 Basic (TIA Portal)  • STEP 7 Professional (TIA Portal)	Yes Yes Yes Yes Yes Yes Yes No No
pre-installed operating system  • Windows CE  Configuration  Message indicator Alarm system (incl. buffer and acknowledgment) Process value display (output) Process value default (input) possible Recipe management Configuration software  • STEP 7 Basic (TIA Portal) • STEP 7 Professional (TIA Portal) • WinCC flexible Compact	Yes Yes Yes Yes Yes Yes Yes No No No
pre-installed operating system  • Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)  Process value display (output)  Process value default (input) possible  Recipe management  Configuration software  • STEP 7 Basic (TIA Portal)  • STEP 7 Professional (TIA Portal)  • WinCC flexible Compact  • WinCC flexible Standard	Yes Yes Yes Yes Yes Yes Yes No No No No No
pre-installed operating system  • Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)  Process value display (output)  Process value default (input) possible  Recipe management  Configuration software  • STEP 7 Basic (TIA Portal)  • STEP 7 Professional (TIA Portal)  • WinCC flexible Compact  • WinCC flexible Standard  • WinCC flexible Advanced	Yes Yes Yes Yes Yes Yes Yes No No No No No No
pre-installed operating system  • Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)  Process value display (output)  Process value default (input) possible  Recipe management  Configuration software  • STEP 7 Basic (TIA Portal)  • STEP 7 Professional (TIA Portal)  • WinCC flexible Compact  • WinCC flexible Standard  • WinCC Basic (TIA Portal)	Yes Yes Yes Yes Yes Yes Yes No
pre-installed operating system  • Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)  Process value display (output)  Process value default (input) possible  Recipe management  Configuration software  • STEP 7 Basic (TIA Portal)  • STEP 7 Professional (TIA Portal)  • WinCC flexible Compact  • WinCC flexible Standard  • WinCC Basic (TIA Portal)  • WinCC Comfort (TIA Portal)	Yes Yes Yes Yes Yes Yes Yes No Yes; from V11
pre-installed operating system  • Windows CE  Configuration  Message indicator Alarm system (incl. buffer and acknowledgment) Process value display (output) Process value default (input) possible Recipe management  Configuration software  • STEP 7 Basic (TIA Portal)  • STEP 7 Professional (TIA Portal)  • WinCC flexible Compact  • WinCC flexible Standard  • WinCC flexible Advanced  • WinCC Basic (TIA Portal)  • WinCC Comfort (TIA Portal)	Yes  Yes  Yes  Yes  Yes  Yes  Yes  You  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
pre-installed operating system  • Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)  Process value display (output)  Process value default (input) possible  Recipe management  Configuration software  • STEP 7 Basic (TIA Portal)  • STEP 7 Professional (TIA Portal)  • WinCC flexible Compact  • WinCC flexible Standard  • WinCC flexible Advanced  • WinCC Basic (TIA Portal)  • WinCC Comfort (TIA Portal)  • WinCC Advanced (TIA Portal)  • WinCC Professional (TIA Portal)	Yes  Yes  Yes  Yes  Yes  Yes  Yes  You  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
pre-installed operating system	Yes  Yes  Yes  Yes  Yes  Yes  Yes  You  Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
pre-installed operating system	Yes  Yes  Yes  Yes  Yes  Yes  Yes  You  No  No  No  No  No  No  No  No  No
pre-installed operating system	Yes  Yes  Yes  Yes  Yes  Yes  Yes  You  No  No  No  No  No  No  No  No  No
pre-installed operating system	Yes Yes Yes Yes Yes Yes Yes No No No No No No No No Yes; from V11 Yes; from V11 Yes; from V11
Pre-installed operating system     Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)  Process value display (output)  Process value default (input) possible  Recipe management  Configuration software      STEP 7 Basic (TIA Portal)     STEP 7 Professional (TIA Portal)      WinCC flexible Compact     WinCC flexible Standard     WinCC flexible Advanced     WinCC Basic (TIA Portal)      WinCC Comfort (TIA Portal)     WinCC Professional (TIA Portal)      WinCC Professional (TIA Portal)      WinCC Professional (TIA Portal)      WinCC Professional (TIA Portal)      WinCC Professional (TIA Portal)  Languages  Online languages      Number of online/runtime languages  Project languages  Languages per project	Yes Yes Yes Yes Yes Yes Yes No No No No No No No No Yes; from V11 Yes; from V11 Yes; from V11
Pre-installed operating system  Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)  Process value display (output)  Process value default (input) possible  Recipe management  Configuration software  STEP 7 Basic (TIA Portal)  STEP 7 Professional (TIA Portal)  WinCC flexible Compact  WinCC flexible Standard  WinCC flexible Advanced  WinCC Basic (TIA Portal)  WinCC Comfort (TIA Portal)  WinCC Advanced (TIA Portal)  WinCC Professional (TIA Portal)  WinCC Professional (TIA Portal)  Tanguages  Online languages  Number of online/runtime languages  Project languages  Languages per project  Functionality under WinCC (TIA Portal)	Yes Yes Yes Yes Yes Yes Yes  No No No No No No No No Yes; from V11 Yes; from V11 Yes; from V11
Pre-installed operating system  Windows CE  Configuration  Message indicator  Alarm system (incl. buffer and acknowledgment)  Process value display (output)  Process value default (input) possible  Recipe management  Configuration software  STEP 7 Basic (TIA Portal)  STEP 7 Professional (TIA Portal)  WinCC flexible Compact  WinCC flexible Standard  WinCC flexible Advanced  WinCC Basic (TIA Portal)  WinCC Comfort (TIA Portal)  WinCC Advanced (TIA Portal)  WinCC Professional (TIA Portal)  WinCC Professional (TIA Portal)  Tanguages  Online languages  Number of online/runtime languages  Project languages  Languages per project  Functionality under WinCC (TIA Portal)  Libraries	Yes Yes Yes Yes Yes Yes Yes  No No No No No No No No Yes; from V11 Yes; from V11 Yes; from V11
pre-installed operating system	Yes Yes Yes Yes Yes Yes Yes No No No No No No No Yes; from V11 Yes; from V11 Yes; from V11 Yes; from V11

Pocket Excel	Yes
PDF Viewer	Yes
Media Player	Yes
<ul> <li>SIMATIC WinCC Sm@rtServer</li> </ul>	Yes
SIMATIC WinCC Audit	Yes
Number of Visual Basic Scripts	Yes
Task planner	
<ul><li>time-controlled</li></ul>	Yes
<ul> <li>task-controlled</li> </ul>	Yes
Help system	
<ul> <li>Number of characters per info text</li> </ul>	70
Message system	
Number of alarm classes	32
Bit messages	
Number of bit messages	4 000
Analog messages	
Number of analog messages	200
S7 alarm number procedure	Yes
System messages HMI	Yes
System messages rivii     System messages, other (SIMATIC S7, Sinumerik,	Yes
Simotion, etc.)	
Number of characters per message	80
Number of process values per message	8
Acknowledgment groups	Yes
Message indicator	Yes
Message buffer	100
Number of entries	1 024
Circulating buffer	Yes
— retentive	Yes
— maintenance-free	Yes
	165
Desine management	
Recipe management	300
Number of recipes	300
<ul><li>Number of recipes</li><li>Data records per recipe</li></ul>	500
<ul><li>Number of recipes</li><li>Data records per recipe</li><li>Entries per data record</li></ul>	500 1 000
<ul> <li>Number of recipes</li> <li>Data records per recipe</li> <li>Entries per data record</li> <li>Size of internal recipe memory</li> </ul>	500 1 000 2 Mbyte
<ul> <li>Number of recipes</li> <li>Data records per recipe</li> <li>Entries per data record</li> <li>Size of internal recipe memory</li> <li>Recipe memory expandable</li> </ul>	500 1 000
<ul> <li>Number of recipes</li> <li>Data records per recipe</li> <li>Entries per data record</li> <li>Size of internal recipe memory</li> <li>Recipe memory expandable</li> </ul> Variables	500 1 000 2 Mbyte Yes
<ul> <li>Number of recipes</li> <li>Data records per recipe</li> <li>Entries per data record</li> <li>Size of internal recipe memory</li> <li>Recipe memory expandable</li> </ul> Variables <ul> <li>Number of variables per device</li> </ul>	500 1 000 2 Mbyte Yes
<ul> <li>Number of recipes</li> <li>Data records per recipe</li> <li>Entries per data record</li> <li>Size of internal recipe memory</li> <li>Recipe memory expandable</li> </ul> Variables <ul> <li>Number of variables per device</li> <li>Number of variables per screen</li> </ul>	500 1 000 2 Mbyte Yes 2 048 400
<ul> <li>Number of recipes</li> <li>Data records per recipe</li> <li>Entries per data record</li> <li>Size of internal recipe memory</li> <li>Recipe memory expandable</li> </ul> Variables <ul> <li>Number of variables per device</li> <li>Number of variables per screen</li> <li>Limit values</li> </ul>	500 1 000 2 Mbyte Yes 2 048 400 Yes
<ul> <li>Number of recipes</li> <li>Data records per recipe</li> <li>Entries per data record</li> <li>Size of internal recipe memory</li> <li>Recipe memory expandable</li> </ul> Variables <ul> <li>Number of variables per device</li> <li>Number of variables per screen</li> <li>Limit values</li> <li>Multiplexing</li> </ul>	500 1 000 2 Mbyte Yes 2 048 400 Yes Yes
<ul> <li>Number of recipes</li> <li>Data records per recipe</li> <li>Entries per data record</li> <li>Size of internal recipe memory</li> <li>Recipe memory expandable</li> </ul> Variables <ul> <li>Number of variables per device</li> <li>Number of variables per screen</li> <li>Limit values</li> <li>Multiplexing</li> <li>Structures</li> </ul>	500 1 000 2 Mbyte Yes 2 048 400 Yes Yes Yes
<ul> <li>Number of recipes</li> <li>Data records per recipe</li> <li>Entries per data record</li> <li>Size of internal recipe memory</li> <li>Recipe memory expandable</li> </ul> Variables <ul> <li>Number of variables per device</li> <li>Number of variables per screen</li> <li>Limit values</li> <li>Multiplexing</li> <li>Structures</li> <li>Arrays</li> </ul>	500 1 000 2 Mbyte Yes 2 048 400 Yes Yes
<ul> <li>Number of recipes</li> <li>Data records per recipe</li> <li>Entries per data record</li> <li>Size of internal recipe memory</li> <li>Recipe memory expandable</li> </ul> Variables <ul> <li>Number of variables per device</li> <li>Number of variables per screen</li> <li>Limit values</li> <li>Multiplexing</li> <li>Structures</li> <li>Arrays</li> </ul> Images	500 1 000 2 Mbyte Yes  2 048 400 Yes Yes Yes Yes Yes
<ul> <li>Number of recipes</li> <li>Data records per recipe</li> <li>Entries per data record</li> <li>Size of internal recipe memory</li> <li>Recipe memory expandable</li> </ul> Variables <ul> <li>Number of variables per device</li> <li>Number of variables per screen</li> <li>Limit values</li> <li>Multiplexing</li> <li>Structures</li> <li>Arrays</li> </ul> Images <ul> <li>Number of configurable images</li> </ul>	500 1 000 2 Mbyte Yes  2 048 400 Yes Yes Yes Yes Yes
Number of recipes Data records per recipe Entries per data record Size of internal recipe memory Recipe memory expandable  Variables  Number of variables per device Number of variables per screen Limit values Multiplexing Structures Arrays  Images  Number of configurable images Permanent window/default	500 1 000 2 Mbyte Yes  2 048 400 Yes Yes Yes Yes Yes
Number of recipes Data records per recipe Entries per data record Size of internal recipe memory Recipe memory expandable  Variables Number of variables per device Number of variables per screen Limit values Multiplexing Structures Arrays  Images  Number of configurable images Permanent window/default Global image	500 1 000 2 Mbyte Yes  2 048 400 Yes Yes Yes Yes Yes
Number of recipes Data records per recipe Entries per data record Size of internal recipe memory Recipe memory expandable  Variables  Number of variables per device Number of variables per screen Limit values Multiplexing Structures Arrays  Images  Number of configurable images Permanent window/default	500 1 000 2 Mbyte Yes  2 048 400 Yes Yes Yes Yes Yes Yes Yes
Number of recipes Data records per recipe Entries per data record Size of internal recipe memory Recipe memory expandable  Variables Number of variables per device Number of variables per screen Limit values Multiplexing Structures Arrays  Images  Number of configurable images Permanent window/default Global image	500 1 000 2 Mbyte Yes  2 048 400 Yes Yes Yes Yes Yes Yes Yes Yes
Number of recipes Data records per recipe Entries per data record Size of internal recipe memory Recipe memory expandable  Variables Number of variables per device Number of variables per screen Limit values Multiplexing Structures Arrays  Images  Number of configurable images Permanent window/default Global image Image selection by PLC	500 1 000 2 Mbyte Yes  2 048 400 Yes
Number of recipes Data records per recipe Entries per data record Size of internal recipe memory Recipe memory expandable  Variables Number of variables per device Number of variables per screen Limit values Multiplexing Structures Arrays  Images  Number of configurable images Permanent window/default Global image Image selection by PLC Image number in the PLC	500 1 000 2 Mbyte Yes  2 048 400 Yes
Number of recipes Data records per recipe Entries per data record Size of internal recipe memory Recipe memory expandable  Variables Number of variables per device Number of variables per screen Limit values Multiplexing Structures Arrays  Images  Number of configurable images Permanent window/default Global image Image selection by PLC Image objects	500 1 000 2 Mbyte Yes  2 048 400 Yes
Number of recipes Data records per recipe Entries per data record Size of internal recipe memory Recipe memory expandable  Variables Number of variables per device Number of variables per screen Limit values Multiplexing Structures Arrays  Images  Number of configurable images Permanent window/default Global image Image selection by PLC Image objects Number of objects per image	500 1 000 2 Mbyte Yes  2 048 400 Yes
Number of recipes Data records per recipe Entries per data record Size of internal recipe memory Recipe memory expandable  Variables Number of variables per device Number of variables per screen Limit values Multiplexing Structures Arrays  Images Number of configurable images Permanent window/default Global image Image selection by PLC Image number in the PLC  Image objects Number of objects per image Text fields I/O fields	500 1 000 2 Mbyte Yes  2 048 400 Yes
Number of recipes Data records per recipe Entries per data record Size of internal recipe memory Recipe memory expandable  Variables Number of variables per device Number of variables per screen Limit values Multiplexing Structures Arrays  Images  Number of configurable images Permanent window/default Global image Image selection by PLC Image number in the PLC  Image objects Number of objects per image Text fields I/O fields Graphic I/O fields (graphics list)	500 1 000 2 Mbyte Yes  2 048 400 Yes Yes Yes Yes Yes Yes 400 Yes Yes Yes Yes Yes Yes Yes Yes
Number of recipes Data records per recipe Entries per data record Size of internal recipe memory Recipe memory expandable  Variables Number of variables per device Number of variables per screen Limit values Multiplexing Structures Arrays  Images Number of configurable images Permanent window/default Global image Image selection by PLC Image number in the PLC  Image objects Number of objects per image Text fields I/O fields	500 1 000 2 Mbyte Yes  2 048 400 Yes
Number of recipes Data records per recipe Entries per data record Size of internal recipe memory Recipe memory expandable  Variables Number of variables per device Number of variables per screen Limit values Multiplexing Structures Arrays  Images  Number of configurable images Permanent window/default Global image Image selection by PLC Image number in the PLC  Image objects Number of objects per image Text fields I/O fields Graphic I/O fields (graphics list) Symbolic I/O fields (text list) Date/time fields	500 1 000 2 Mbyte Yes  2 048 400 Yes
<ul> <li>Number of recipes</li> <li>Data records per recipe</li> <li>Entries per data record</li> <li>Size of internal recipe memory</li> <li>Recipe memory expandable</li> </ul> Variables <ul> <li>Number of variables per device</li> <li>Number of variables per screen</li> <li>Limit values</li> <li>Multiplexing</li> <li>Structures</li> <li>Arrays</li> </ul> Images <ul> <li>Number of configurable images</li> <li>Permanent window/default</li> <li>Global image</li> <li>Image selection by PLC</li> <li>Image number in the PLC</li> </ul> Image objects <ul> <li>Number of objects per image</li> <li>Text fields</li> <li>I/O fields</li> <li>Graphic I/O fields (graphics list)</li> <li>Symbolic I/O fields (text list)</li> <li>Date/time fields</li> <li>Switches</li> </ul>	500 1 000 2 Mbyte Yes  2 048 400 Yes
Number of recipes Data records per recipe Entries per data record Size of internal recipe memory Recipe memory expandable  Variables Number of variables per device Number of variables per screen Limit values Multiplexing Structures Arrays  Images  Number of configurable images Permanent window/default Global image Image selection by PLC Image number in the PLC  Image objects Number of objects per image Text fields I/O fields Graphic I/O fields (graphics list) Symbolic I/O fields (text list) Date/time fields	500 1 000 2 Mbyte Yes  2 048 400 Yes

• Icons	Yes
Geometric objects	Yes
Complex image objects	165
	20
<ul><li>Number of complex objects per screen</li><li>Alarm view</li></ul>	Yes
Trend view	Yes
User view	Yes
Status/control	Yes
Sm@rtClient view	Yes Yes
<ul><li>Recipe view</li><li>f(x) trend view</li></ul>	Yes
• •	Yes
System diagnostics view     Modia Player	Yes
Media Player     Par graphs	Yes
<ul><li>Bar graphs</li><li>Sliders</li></ul>	Yes
Pointer instruments	Yes
	Yes
Analog/digital clock     Links	Tes
Lists  • Number of text lists per project	500
<ul><li>Number of text lists per project</li><li>Number of entries per text list</li></ul>	500 500
Number of graphics lists per project     Number of entries per graphics list	500
Number of entries per graphics list  Archiving	500
	50
Number of archives per device     Number of archives per archives.	20 000
<ul><li>Number of entries per archive</li><li>Message archive</li></ul>	Yes
Process value archive	Yes
	165
<ul><li>Archiving methods</li><li>— Sequential archive</li></ul>	Yes
Sequential arctive  — Short-term archive	Yes
	Tes
Memory location	Yes
Memory card      USB memory	Yes
— Ethernet	Yes
Data storage format	165
— CSV	Yes
— CSV — TXT	Yes
— RDB	Yes
	Tes
Security  • Number of user groups	50
Number of user rights	32
Number of users  Number of users	50
Password export/import	Yes
SIMATIC Logon	Yes
Logging through printer	100
Alarms	Yes
Report (shift log)	Yes
Report (stiff log)     Hardcopy	Yes
Electronic print to file	Yes; PDF, HTML
Character sets	100, 1 DI , IIIIVIL
Keyboard fonts	
- US English	Yes
Transfer (upload/download)	160
MPI/PROFIBUS DP	Yes
WENTROFIBUS DP      USB	Yes
Ethernet	Yes
	Yes No
using external storage medium  Process coupling	IVO
1 100033 COUPING	

• S7-1200	Yes
• S7-1500	Yes
• S7-200	Yes
• S7-300/400	Yes
• LOGO!	Yes
<ul><li>WinAC</li></ul>	Yes
• SINUMERIK	Yes; with SINUMERIK option package
• SIMOTION	No; With WinCC, subsequent version
<ul> <li>Allen Bradley (EtherNet/IP)</li> </ul>	Yes
<ul><li>Allen Bradley (DF1)</li></ul>	Yes
<ul> <li>Mitsubishi (MC TCP/IP)</li> </ul>	Yes
<ul><li>Mitsubishi (FX)</li></ul>	Yes
OMRON (FINS TCP)	No
<ul> <li>OMRON (LINK/Multilink)</li> </ul>	Yes
<ul> <li>Modicon (Modbus TCP/IP)</li> </ul>	Yes
<ul><li>Modicon (Modbus)</li></ul>	Yes
Service tools/configuration aids	
Backup/Restore manually	Yes
<ul> <li>Backup/Restore automatically</li> </ul>	Yes
<ul><li>Simulation</li></ul>	Yes
Device switchover	Yes
Peripherals/Options	
Printer	Yes
SIMATIC HMI MM memory card: Multi Media Card	Yes
SIMATIC HMI SD memory card: Secure Digital memory card	Yes
USB memory	Yes
Mechanics/material	
Enclosure material (front)	
Plastic	No
<ul> <li>Aluminum</li> </ul>	Yes
Stainless steel	No
Dimensions	
Width of the housing front	214 mm
Height of housing front	158 mm
Mounting cutout, width	197 mm
Mounting cutout, height	197 111111
	141 mm
Overall depth	
Overall depth Weights	141 mm
Weights	141 mm
	141 mm 63 mm

last modified: 1/16/2021 **C**